



Government of Liberia
MILLENNIUM CHALLENGE ACCOUNT LIBERIA

RESPONSES TO REQUEST FOR CLARIFICATION

**Provision of Refurbishment Works to the Permanent Office of Liberia
Electricity Regulatory Commission (LERC)**

Ref. No. 4A1506/LERC/002

Following the issuance of the Request for Quotation (RFQ) document for the **Provision of Refurbishment Works to the Permanent Office of Liberia Electricity Regulatory Commission (LERC)** on December 10, 2020, Suppliers requested for clarifications related to the RFQ document in writing.

The requests for clarifications received from Suppliers and responses are indicated below:

QUESTIONS & ANSWERS

#	Item Ref	Suppliers' Queries	MCA-Liberia's Response
1	Lot 3 – BoQ Item 1.4	Enet Channel - Please make some clarity as per size or indicate the specific size as per your desire	Refer Addendum #1
2	Lot 3 – BoQ Item 1.5	Enet 20*40 - We will also need some clarity too on this as to whether 20x40 or 25x40 channel	Refer Addendum #1
3	Lot 3 – BoQ Item 1.6	Modules - Modules are trunking accessories which comprise of the following: Adjustable internal angle, external angle. Angle plate, "T" branch, end cover etc. On this note, please make us some clarity as well.	Modules is what the key stone jack is inserted in.
4	Lot 3 – BoQ Item 1.7	Face plate - Double or single face plate?	Refer Addendum #1
5	Lot 3 – BoQ Item 1.11	Tape for electrical purpose (1inch width and 66 feet long approximately) - Is there no room for masking tape for labelling of cables which is mostly use for network cabling instead of electrical cable? Please make clarity	There is no room for masking tape. We will be using a labelling machine.

#	Item Ref	Suppliers' Queries	MCA-Liberia's Response
6	Lot 3 – BoQ Item 1.12	Flexible tube (each roll of 13 meters) - Please indicate size	Refer Addendum #1
7	Lot 3 – BoQ Item 1.18	Fiber cable - Please indicate size	Refer Addendum #1
8	Lot 3 – BoQ Item 1.19	Cable shoe - Please indicate size	Refer Addendum #1
9	Lot 3 – BoQ Item 1.20	Cable trail - Please indicate size	Refer Addendum #1
10	Lot 3 – BoQ Item 1.23	End Cover- From my understanding, the end cover should be or is the module that close the corner Channel at the end	Yes
11	Lot 3 – BoQ Item 1.24	Conor cover - While a corner is a channel itself, so speaking of corner cover, we will need some clarity as well	The corner cover is used to cover the channel where two walls meet in a room.
12	Lot 3 BoQ	<p>Please also state that the below will be provided by you or we are to quote for them as well</p> <ol style="list-style-type: none"> 1. There is no request for cable in the BOM 2. There is no request for rack whether 12U, 9U, 6U or 4U in the BOM 	We will be providing our own CAT7 Cable as well a rack for our equipment.