

SPECIFIC PROCUREMENT NOTICE

ADDENDUM #1

to

REQUEST FOR QUOTATION (RFQ)

for

Supply and Delivery of Three Phase 4 Wire LV CT Connected Smart Prepayment/Switch Meter Enclosure fitted with a Smart MCCB (Molded Case Circuit Breaker) for Liberia Electricity Corporation (LEC)

Addendum Date: January 15, 2020	Ref# Number: 4A30/PSD/004
RFQ Date: December 18, 2019	Project Name: Energy Project
Country: Liberia	Funding Agency: Millennium Challenge Corporation
City/Locality: Monrovia	Employer: Millennium Challenge Account – Liberia (MCA-Liberia)

The following changes are hereby made to the above-mentioned Request for Quotation (RFQ):

1. Annex 1, Technical Specifications:

Item 6.10 power supply variation (Page 6): 6.10.1 Voltage: -70% to +20% is replaced with -40% to +20%.

Item 7. General mechanical requirements (Page 7): 7.7 and 7.8: A variation of +5% to the indicated dimensions of meter and window is acceptable.

Item 31. Software (Page 23): Note: The following sentence is added to the Note.


“The server-client (AMI) application is not included but the meters provided should be AMI ready and compliant, with a GPRS modem installed in the meter.”

Item 40. Communicating with HHU (Hand Held Unit) (Page 28): The following point is added.

“**40.8** 5 (five) compatible HHUs will be required.”

2. All other items and paragraphs of the subject RFQ Document remain unchanged.

Yours Sincerely,



Mr. Monie R. Captan
Chief Executive Officer
Millennium Challenge Account – Liberia